



Texas  
Water Utilities

A SouthWest Water Company

# 2021 Drinking Water Quality Report

(Consumer Confidence Report)



## What's inside?

This is an annual, overall summary report of the water quality in your area that explains the source of your water, test results and general information for those with health concerns. The analysis was made using the data from the most recent U.S. Environmental Protection Agency (EPA) required tests and is presented in the attached pages. We hope this information helps you become more knowledgeable about what's in your drinking water. If you have any questions concerning water quality or the source of your water, please call our Regulatory Department at (512) 219-2294.

**Our drinking water meets or  
exceeds all federal (EPA)  
drinking water requirements.**



**Special Notice for the ELDERLY, INFANTS, CANCER PATIENTS, people with HIV/AIDS or other immune problems:** You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly or immune-compromised persons such as those undergoing chemotherapy for cancer; those who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care provider. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (1-800-426-4791).


Water empowered. <sup>SM</sup>

**En Español: Este informe incluye información importante sobre el agua potable. Si tiene preguntas o comentarios sobre éste informe en español, favor de llamar al tel 1-866-654-7992 para hablar con una persona bilingüe en español.**

P.W.S.

## Your Water Source

### ON THE MAP



### Lake Sources

- |                       |                          |
|-----------------------|--------------------------|
| 1 Possum Kingdom Lake | 8 Lake Palestine         |
| 2 Lake Travis         | 9 Lake Granbury          |
| 3 Lake Austin         | 10 Lake Texoma           |
| 4 Lake Pflugerville   | 11 Lake Randell          |
| 5 Lake Dunlap         | 12 Lake Livingston       |
| 6 Canyon Lake         | 13 Lake Houston          |
| 7 Lake Bridgeport     | 14 Cedar Creek Reservoir |

\*These aquifers were too small to put on this map, but check them out online!

**Public Participation Opportunities:** The Utility does not hold regularly scheduled meetings. However, if you wish to contact the owners, please call our Customer Care at 866-654-7992.

## TYPES OF SOURCES

ivers

lakes

streams

ponds

reservoirs

springs

wells

## What is ground water?

The water found underground in the cracks and spaces in soil, sand and rock. It is stored in and moves slowly through geologic formations of soil, sand and rocks called aquifers.

## What's the water quality before treatment?

The ground water we use has less contaminants than surface water because there is not much human interaction. Therefore, the water does not require as much filtration as our surface water.

## Why are there contaminants?

As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water before treatment include: microbes, inorganic contaminants, pesticides, herbicides, radioactive contaminants, and organic chemical contaminants. Therefore, **all drinking water may contain contaminants**. The Texas Commission on Environmental Quality (TCEQ) completed an assessment of our source water and the results indicate that some of our sources are susceptible to certain contaminants. The sampling requirements for our water system are based on this susceptibility and previous sample data. Any detection of these contaminants will be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system, please contact us.

# HOW IS GROUND WATER TREATED?

1

### Starts With the Source

Water comes in pumped through a well from your local aquifer.

### Cleaning the Water

Water is treated and sanitized with chlorine. This process is called chlorination. It is an effective way to kill naturally-occurring germs in ground water, and is a common practice by most systems.

2

3

### Ends at Your Tap

Once the water has been cleaned, it goes into a ground storage tank and is ready for you to turn on your tap.



1: Well



2: Chlorination



3: Storage Tank

# What are the charts about?

The charts on the pages that follow list all of the federally regulated or monitored contaminants which have been found in your drinking water. The U.S. EPA requires water systems to test for up to 97 contaminants.

## How to read the charts:

From left to right, you will see the year the water was required to be tested, the contaminant we tested for, the amount detected within the water, the acceptable level developed by the EPA, and the source of the mentioned contaminant. For an even more detailed explanation, below are the definitions of the terms used within the charts.

## DEFINITIONS

### Maximum Contaminant Level Goal (MCLG)

The level of a contaminant in drinking water below which there is no known or expected health risk. MCLGs allow for a margin of safety before the contaminant reaches a harmful level.

### Maximum Contaminant Level (MCL)

The highest allowable level of a contaminant in drinking water. MCLs are set as close to the MCLGs as possible using the best available treatment technology.

### Maximum Residual Disinfectant Level Goal (MRDLG)

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

### Maximum Residual Disinfectant Level (MRDL)

The highest level of disinfectant allowed in drinking water. There is convincing evidence that an addition of a disinfectant is necessary for control of microbial contaminants.

### Treatment Technique (TT)

A required process intended to reduce the level of a contaminant in drinking water.

### Action Level (AL)

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

### Secondary Constituents

Many constituents (such as calcium, sodium or iron) which are often found in drinking water can cause taste, color, and odor problems. The taste and odor constituents are called secondary constituents and are regulated by the State of Texas, not the EPA. These constituents are not causes for health concern. Therefore, secondaries are not required to be reported in this document but they may greatly affect the appearance and taste of your water.

### Abbreviations

NTU – Nephelometric Turbidity Units  
MFL – million fibers per liter (a measure of asbestos)  
pCi/L – picocuries per liter (a measure of radioactivity)  
ppm – parts per million, or milligrams per liter (mg/L)  
ppb – parts per billion, or micrograms per liter (µg /L)  
ppt – parts per trillion, or nanograms per liter  
ppq – parts per quadrillion, or picograms per liter

**Want more day-to-day  
water facts and info?**

**Visit: [www.swwc.com/  
h2ome](http://www.swwc.com/h2ome)**

**Inorganic Contaminants**

| Year | Contaminant    | Our Average Level | Minimum Level | Maximum Level | MCL | MCLG | Typical Source                                                                                                             |
|------|----------------|-------------------|---------------|---------------|-----|------|----------------------------------------------------------------------------------------------------------------------------|
| 2021 | Arsenic (ppb)  | 4.85              | 4.6           | 5.1           | 10  | 0    | Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes.                    |
| 2021 | Barium (ppm)   | 0.311             | 0.298         | 0.323         | 2   | 2    | Discharge of drilling wastes, discharge from metal refineries; erosion of natural deposits.                                |
| 2021 | Fluoride (ppm) | 0.345             | 0.33          | 0.36          | 4   | 4    | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories. |
| 2021 | Selenium (ppb) | 4.0               | 3.4           | 4.6           | 50  | 50   | Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines.                          |

**Radioactive Contaminants**

| Year | Contaminant                 | Our Average Level | Minimum Level | Maximum Level | MCL | MCLG | Typical Source                          |
|------|-----------------------------|-------------------|---------------|---------------|-----|------|-----------------------------------------|
| 2021 | Gross alpha (pCi/L)         | 14.43             | 13.4          | 15.2          | 15  | 0    | Erosion of natural deposits.            |
| 2021 | Gross beta emitters (pCi/L) | 4.8               | 4.0           | 5.6           | 50  | 0    | Decay of natural and man-made deposits. |
| 2021 | Combined Radium (ppb)       | 4.027             | 3.8           | 4.47          | 5   | 0    | Erosion of natural deposits.            |
| 2021 | Combined Uranium (ppb)      | 1.65              | 1.4           | 1.9           | 30  | 0    | Erosion of natural deposits.            |

**Volatile Organic Contaminants**

| Year | Contaminant   | Our Average Level | Minimum Level | Maximum Level | MCL | MCLG | Typical Source                                                         |
|------|---------------|-------------------|---------------|---------------|-----|------|------------------------------------------------------------------------|
| 2021 | Xylenes (ppm) | 0.0011            | 0.0005        | 0.0016        | 10  | 10   | Discharge from petroleum factories; discharge from chemical factories. |

**Maximum Residual Disinfectant Level**

| Year | Disinfectant            | Our Average Level | Minimum Level | Maximum Level | MRDL | MRDLG | Typical Source                        |
|------|-------------------------|-------------------|---------------|---------------|------|-------|---------------------------------------|
| 2021 | Chlorine Residual (ppm) | 1.64              | 0.49          | 2.90          | 4.00 | 4.00  | Disinfectant used to control microbes |

**Unregulated Initial Distribution System Evaluation for Disinfection Byproducts (DBP2)**

TESTING WAIVED, NOT REPORTED, OR NONE DETECTED

**Unregulated Contaminants** NOT REPORTED OR NONE DETECTED**Lead and Copper**

| Year | Contaminant | 90% of Test Levels Were Less Than | # of Tests With Levels Above EPA's Action Levels | Action Level | Unit of Measure | Typical Source                                                                                          |
|------|-------------|-----------------------------------|--------------------------------------------------|--------------|-----------------|---------------------------------------------------------------------------------------------------------|
| 2020 | Lead        | 3.71                              | 0                                                | 15           | ppb             | Corrosion of household plumbing systems; erosion of natural deposits.                                   |
| 2020 | Copper      | 0.316                             | 0                                                | 1.3          | ppm             | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives. |

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This water supply is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

#### **Turbidity** NOT REQUIRED

#### **Total Coliform**

| Year | Contaminant             | Highest Monthly Number of Positive Samples | MCL | Unit of Measure | Typical Source                        |
|------|-------------------------|--------------------------------------------|-----|-----------------|---------------------------------------|
| 2021 | Total Coliform Bacteria | 1                                          | *   | Presence        | Naturally present in the environment. |

#### **Fecal Coliform**

E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, some of the elderly, and people with severely-compromised immune systems.

| Year | Contaminant             | Highest Monthly Number of Positive Samples | MCL | Unit of Measure | Source of Contaminant             |
|------|-------------------------|--------------------------------------------|-----|-----------------|-----------------------------------|
| 2021 | Fecal Coliform Bacteria | 1                                          | *   | Presence        | Present in animal or human waste. |

**\*Two or more coliform found samples in any single month.**

#### **Secondary and Other Constituents Not Regulated** (No associated adverse health effects)

| Year | Contaminant                                 | Our Average Level | Minimum Level | Maximum Level | Limit | Typical Source                                                                                         |
|------|---------------------------------------------|-------------------|---------------|---------------|-------|--------------------------------------------------------------------------------------------------------|
| 2021 | Calcium (ppm)                               | 103.4             | 98.8          | 108           | NA    | Abundant naturally occurring element.                                                                  |
| 2021 | Chloride (ppm)                              | 64.5              | 62            | 67            | 300   | Abundant naturally occurring element; used in water purification; byproduct of oil field activity.     |
| 2017 | Copper (ppm)                                | 0.008             | 0.002         | 0.0148        | 1     | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |
| 2021 | Iron (ppm)                                  | 0.286             | 0.282         | 0.29          | 0.3   | Erosion of natural deposits; iron or steel water delivery equipment.                                   |
| 2021 | Magnesium (ppm)                             | 7.785             | 7.71          | 7.86          | NA    | Abundant naturally occurring element.                                                                  |
| 2021 | Manganese (ppm)                             | 0.051             | 0.049         | 0.053         | 0.05  | Abundant naturally occurring element.                                                                  |
| 2021 | Nickel (ppb)                                | 1.95              | 1.8           | 2.1           | 100   | Erosion of natural deposits.                                                                           |
| 2021 | Sodium (ppm)                                | 32.4              | 30.3          | 34.5          | NA    | Erosion of natural deposits; byproduct of oil field activity.                                          |
| 2021 | Sulfate (ppm)                               | 8                 | 8             | 8             | 300   | Naturally occurring; common industrial byproduct; byproduct of oil field activity.                     |
| 2021 | Total Alkalinity as CaCO <sub>3</sub> (ppm) | 274.5             | 264           | 285           | NA    | Naturally occurring soluble mineral salts.                                                             |

|      |                                        |       |       |       |      |                                                                                    |
|------|----------------------------------------|-------|-------|-------|------|------------------------------------------------------------------------------------|
| 2021 | Total<br>Dissolved<br>Solids<br>(ppm)  | 459   | 454   | 464   | 1000 | Total dissolved mineral constituents<br>in water.                                  |
| 2021 | Total<br>Hardness as<br>CaCO3<br>(ppm) | 290   | 278   | 302   | NA   | Naturally occurring calcium.                                                       |
| 2021 | Zinc<br>(ppm)                          | 0.010 | 0.007 | 0.012 | 5    | Moderately abundant naturally<br>occurring element; used in the metal<br>industry. |